

Town of Tisbury Wastewater Department P.O. Box 788, 115 High Point Road Vineyard Haven, Ma. 02568 Phone (508) 696-4220 Fax: (508) 696-4221

Incident Report

Report By:	Jared Me	ader		Incident Date:	9/9/2021	Incident Time:	14:27	
Title/Role:	Superint	endent_		Street Address:	25 Beach Road			
Specific Area of Location:		on:	Grinder pump chamber located	h Road				
Town Staff Present: Kirk		Kirk M	letell, DPW Director		_			
Micha		Micha	el Alberice, Wastewater Lead O	perator	_			
		Cather	rine Fuller, Board of Health		_			

Incident Description:

Sanitary Sewer Overflow from a grinder pump station due to an illicit connection to the wastewater collection

system, resulting in wastewater entering the stormwater collection system and discharging to the harbor.

Notifications:

X	EPA	X	DEP	X	DMF	X	вон
X	Cons. Comm.	X	Water Dept.	X	Harbor Master	X	Shellfish Dept.
X	Fire Dept.	X	WRC	X	Sewer Advisory	X	

NARRATIVE

At approximately 14:30, on September 9, 2021. The Tisbury Wastewater received a report from the Dukes County Sheriff's Officer Communications Center, of a strong odor coming from around the area of Art Cliff Diner. Michael Alberice, responded to the location to investigate the cause. Upon his arrival he immediately detected the smell of wastewater in the air and began searching for the cause. A few minutes after Mikes arrived at the Art Cliff Diner, I received another call from the Communications Center informing us that another complaint of a strong odor was coming from the area of the Citco station on Beach Road. I called Mike and informed him of the updated information and told him I was gathering equipment that might be needed.

When Mike arrived at the grinder pump station at 19 Beach Road, he immediately noticed water coming up from the Bilco Hatch that houses the grinder pump connected to the low-pressure sewer collection system. Once I received this information, I called Maciel and Son asking them if they could one of their trucks down to the area of 19 Beach Road and to bring what equipment he might need to cut the road to gain access to curb boxes that might have been paved over. Mike then informed me that the grinder pumps inside the chamber were completely submerged and not operating in auto and that he was manually pumping the chamber down, but it did not seem to be slowing the flow of water. When I arrived at the location, I began Looking of the location of the curb box. Mike then came over to assist in the search and said Kirk Metell was manually pumping down the chamber. Within minutes Maciel and son arrived and began pumping out the station with Mike. At approximately 15:00, the overflow was stopped from spilling out onto the property. Once the chamber was pumped down it was discovered that a large volume of water was coming into the chamber and that it was consistent with the type of flow that should becoming from any of the four-building listed on the as-builts. Catherine Blake who was previously on location also investigating the odor small went and retrieved and old title five map for the properties which gave us a better understanding. We discovered while using Maciels CCTV that the solids tank from the title five were still intact and attached to the sewer but was inaccessible due to paving. At this point I instructed Troy Maciel to cut the driveway and expose the tank so we can get a look at what was going on.

While Troy and his crew was cutting the driveway, we started suspecting that their was an illicit connection (sump pump) attached to the system because the flow was increasing and decreasing in a fairly steady pattern and so we began to search the buildings with the new property manager who arrived on location. We were able to identify that their was flow in the pipe because we can hear it and feel the vibration in the pipes. But we were not able to locate the pump.


After gaining access to the solids tank, we again used the CCTV and confirmed that the flow was coming from 25 Beach Road and was consistent with a sump pump. After Searching for approximately three hours of searching, turning on and off breakers try to stop the pump. Trevor Maciel felt that the floor was different under a rug he was standing on and pulled it to the side which revealed a hatch cut in the floor and once removed, confirmed our suspicions.

The following morning after the heavy rains, Mike disinfected the property while I began completing the DEP SSO reporting process. EOR

Respectfully,

Jared a Meade

Jared A. Meader Superintendent Tisbury Wastewater Department



Other:

4. SSO Discharge to: Ground Surface (no release to surface water)

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key



See DEP **Regional Office** telephone and fax numbers at the end of this form.

Massachusetts Department of Environmental Protection	
Bureau of Water Protection – Wastewater Management Program	
Sanitary Sewer Overflow (SSO)/Bypass	

FOR DEP USE ONLY

Tax Identification Number

[]pm

√pm

√ pm

Form- SSO Notifications	, revised.doc	• rev.	01/2013
-------------------------	---------------	--------	---------

Backup into Property

Direct to Receiving Water

Catch basin to Receiving Water

Backup into Property Basement

Wastewater Overflow/Bypass or Sewage Backup Notification • Page 1 of 3

Vineyard Haven Harbor

(specify)

(surface water)

(surface water)



Massachusetts Department of Environmental Protection FOR DEP USE ONLY Bureau of Water Protection – Wastewater Management Program Sanitary Sewer Overflow (SSO)/Bypass Tax Identification Number **Notification Form** C. SSO Information (cont.) 25 Beach Road (Chamber located behind 19 Beach Road) Location: (Description of discharge site or closest address) 300 gal. 5. Estimated SSO Volume at time of this Report: Estimated tank capacity Method of Estimating Volume: 6. Cause of SSO Event: Insufficient Capacity in System Pump Station Failure Rain Event Treatment Unit failure Sewer System Blockage: Dipe Collapse Root Intrusion Grease Blockage Illicit sump pump connection Other: (Specify) 7. Corrective Actions Taken: Manually pumped down grinder chamber until septic hauler (Maciel and Sons) arrived and vacuumed chamber. Cut driveway to expose old septic solids tank to allow CCTV access inorder to identify I&I source. Located and disconnected sump pump located in a crawl space at 25 Beach Road. No No Impact Area cleaned and/or disinfected: Ves Disinfected area using a 10 to 1 Beach mix the following morning after the rain stopped. No No 🖌 Yes **Corrective Actions Completed:** Disconnected sump pump and repaired grinder chamber swithces. D. Comments/Attachments/Follow-up I wish to provide (select all that apply): No additional comments or attachments Attachment Additional comments below:

Additional comments and planned actions:

The Building Department has been notified and will be following up with 25 Beach

Road to ensure that pump and unrelated piping has been removed.



Massachusetts Department of Environmental Protection Bureau of Water Protection - Wastewater Management Program Sanitary Sewer Overflow (SSO)/Bypass **Notification Form**

FOR DEP USE ONLY

Tax Identification Number

E. Certification Statement

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Signature of Authorized Representative

9/10/2021

Date Signed

Please keep a copy of this report for your records. When submitting additional information, include the MassDEP Incident Number from this report.

MassDEP Regional Office and EPA Telephone and Fax Numbers:

Northeast Region	Phone: 978-694-3215	Fax: 978-694-3499
Southeast Region	Phone: 508-946-2750	Fax: 508-947-6557
Central Region	Phone: 508-792-7650	Fax: 508-792-7621
Western Region	Phone: 413-784-1100	Fax: 413-784-1149
EPA	Phone: 617-918-1510	
EPA for Southeast Region, David Turin	Phone: 617-918-1598	Fax: 617-918-0598
EPA for Northeast, Central and Western Regions, Douglas Koopman	Phone: 617-918-1747	Fax: 617-918-0747
DEP 24-hour emergency	Phone: 888-304-1133	



Grinder Chamber



Cutting drive way to gain access to old solids tank/grease trap



Sump pump located under a trap door in the floor covered with carpet.